



NOTE :
CIRCUIT 1 AND 2 TO BE
PROVIDED WITH CONTACTOR

FEEDER CABEL 3x4C/10 mm2+1x6 mm2(G)
FROM MDB (IN AGL STATION)

GOVERNMENT OF THE
COMMONWEALTH OF DOMINICA
MINISTRY OF COMMUNICATIONS WORKS AND HOUSING
REPRESENTED BY:
THE NATIONAL AUTHORSING OFFICER
OF THE
EUROPEAN DEVELOPMENT FUND

MELVILLE HALL AIRPORT
DOMINICA AIR ACCESS IMPROVEMENT PROJECT
TENDER DOSSIER

SCALE : AS SHOWN
DATE : NOV. 2005

DWG.No. : P5-106

NACO **CEEP**

TITLE : PACKAGE 5: EQUIPMENT SUPPLY
INLINE DIAGRAM DISTRIBUTION BOARD

DRAWN :	NOV. 2005	AHO	PROJ. No. :	212.001	SIZE :
CHECKED :	NOV. 2005	AM	FILE :	212001_P5-106.DWG	A3
APPROVED :	NOV. 2005	DE			